

## D6.1 Appendix D Summary Sheet

### D6.1 Appendix D Details

Type of Document:	D6.1 Appendix D
Document Reference #:	HUSA Chamartín hotel
Title:	Identification and definition of BaaS demonstration buildings
Version Number:	1.1
Preparation Date:	August 30, 2013
Delivery Date:	September 6, 2013
Author(s):	Javier Martín (DALKIA)
Document Identifier:	baas_wp6_d6.1_pilotsidentificationdefinition_appendixd_husa_1.1.docx
Document Status:	Final (Resubmission)
Dissemination Level:	PU - Public

### D6.1 Appendix D HUSA Chamartín hotel: Short Description

This document describes the demonstration building HUSA Chamartín Hotel.

Keywords: HUSA, Chamartín, hotel, Madrid, demonstration building

### Copyright notices

© 2013 BaaS Consortium Partners. All rights reserved. BaaS is an FP7 Project supported by the European Commission under contract #288409. For more information on the project, its partners, and contributors please see <http://www.baas-project.eu/>. You are permitted to copy and distribute verbatim copies of this document, containing this copyright notice, but modifying this document is not allowed. All contents are reserved by default and may not be disclosed to third parties without the written consent of the BaaS partners, except as mandated by the European Commission contract, for reviewing and dissemination purposes. All trademarks and other rights on third party products mentioned in this document are acknowledged and owned by the respective holders. The information contained in this document represents the views of BaaS members as of the date they are published. The BaaS consortium does not guarantee that any information contained herein is error-free, or up to date, nor makes warranties, express, implied, or statutory, by publishing this document.

## Table of Contents

Appendix D: Husa Chamartin Hotel. Madrid (Spain).....	5
1.1 General building information .....	5
2 Building use: distribution and occupancy.....	8
3 Building characteristics.....	16
3.1 Envelope elements and thermal characteristics .....	16
4 Energy flow.....	17
5 Energy supply and use .....	19
5.1 Electricity supply and consumption.....	19
5.2 Fuel supply and consumption .....	20
6 Building Management System.....	21
6.1 Energy generation monitoring and control .....	21
6.2 Control strategies .....	23
6.2.1 <i>Heating and cooling system</i> .....	23
6.2.2 <i>Generation level existing control</i> .....	30
7 Historical data: existing data base.....	33
7.1 Existing data base .....	33
7.2 Existing historical variables.....	33
8 External data sources: weather data .....	36

## List of Figures

Figure 1: HUSA Chamartín Hotel location .....	5
Figure 2: Aereal view of HUSA Chamartín Hotel and Railway Station.....	5
Figure 3: Hydrographic map of the Madrid Region .....	6
Figure 4: Floor +0.00 plan.....	8
Figure 5: Floor +3.30 plan.....	9
Figure 6: Floor +6.60 plan.....	10
Figure 7: Floor +9.90 plan.....	11
Figure 8: Floor +13.05 plan.....	11
Figure 9: Floor +16.35 plan.....	12
Figure 10: Floor +19.25 plan.....	13
Figure 11: Floor 7 to 16 plan .....	13
Figure 12: Building daily occupation .....	14
Figure 13: Building yearly occupation .....	15
Figure 14: Energy flow.....	17
Figure 15: Hydraulic scheme for heating and cooling system.....	17
Figure 16: Electricity consumption for cooling system .....	19
Figure 17: Heat production management of HCH.....	21
Figure 18: Cold production management of HCH.....	22
Figure 19: Strategy for boiler start .....	23
Figure 20: Strategy for boilers sequencing .....	24
Figure 21: Strategy for boiler power limitation .....	24
Figure 22: Strategy for boilers rotation by impairments.....	25
Figure 23: Strategy for gas meter .....	25
Figure 24: Strategy for fan tower .....	26
Figure 25: Strategy for energy balance.....	26
Figure 26: Strategy for boilers thermal energy .....	27
Figure 27: Strategy for DHW pumps starts .....	27
Figure 28: Strategy for DHW pumps operating hours .....	28
Figure 29: Strategy for cooling units' electrical consumption.....	28
Figure 30: Strategy for cooling units thermal energy counters.....	29
Figure 31: Strategy for cooling units' production yields .....	29
Figure 32: Heat generation scheme .....	30
Figure 33: Cooling generation scheme .....	31
Figure 34: Boiler flow temperature .....	34

## List of Tables

Table 1: General information of HUSA Chamartin building .....	6
Table 2: Climate values for Madrid .....	7
Table 3: HCH building distribution / usage floor +0.00 .....	8
Table 4: HCH building distribution / usage floor +3.30 .....	9
Table 5: HCH building distribution / usage floor +6.60 .....	10
Table 6: HCH building distribution / usage floor +9.90 .....	11
Table 7: HCH building distribution / usage floor +13.05 .....	11
Table 8: HCH building distribution / usage floor +16.35 .....	12
Table 9: HCH building distribution / usage floor +19.25 .....	13
Table 10: HCH building distribution / usage floor 7 to 16 .....	13
Table 11: Building daily occupation profile of HUSA Chamartin building .....	14
Table 12: Building yearly occupation profile of HUSA Chamartin building .....	14
Table 13: Construction elements of HUSA Chamartin building.....	16
Table 14: Windows description of HUSA Chamartin building .....	16
Table 15: Energy flow elements of HUSA Chamartin building .....	18
Table 16: Information about electricity supply of HUSA Chamartin building .....	19
Table 17: Electricity consumption of HUSA Chamartin building .....	19
Table 18: Information about fuel supply of HUSA Chamartin building.....	20
Table 19: Gas consumption of HUSA Chamartin building .....	20
Table 20: BMS installed devices and power balance of HUSA Chamartin building.....	22
Table 21: Systems level control strategies of HUSA Chamartin building .....	23
Table 22: Boiler related sensors.....	30
Table 23: Boiler related control .....	31
Table 24: Chiller related sensors .....	31
Table 25: Chiller related control .....	32
Table 26: Consumed energy parameters of HUSA Chamartin building .....	33
Table 27: Delivered energy parameters of HUSA Chamartin building .....	33
Table 28: Indoor ambient parameters of HUSA Chamartin building .....	34
Table 29: Outdoor ambient parameters of HUSA Chamartin building.....	36


## Appendix D: Husa Chamartin Hotel. Madrid (Spain)

HUSA Chamartín Hotel is a four stars hotel located in Madrid, Spain. The hotel has a capacity of 387 rooms and his area is 35.000 m<sup>2</sup>.



**Figure 1: Husa Chamartín Hotel location**

HUSA Chamartín Hotel is located closed to Chamartín Railway Station and 16 floors, 9 of this dedicated to accommodation. It was originally built for offices, but change for hotel use during construction.




**Figure 2: Aereal view of Husa Chamartín Hotel and Railway Station**

### 1.1 General building information

HUSA Chamartín Hotel (HCH) is located in Madrid, the capital of Spain, with over 3.250.000 inhabitants, in the center of Spain.

The city of Madrid is located over the Manzanares river basin and a few kilometers from the Sierra Guadarrama, at an altitude of 667 meters.



**Figure 3: Hydrographic map of the Madrid Region**

Madrid's climate is Mediterranean-continental type influenced by urban conditions. Winters are cold, with temperatures below 4-5 ° C, frequent frost and snow. Summers are hot with averages around 24 ° C in July and August, with highs, on time and in batch, can reach 35 ° C.

The daily oscillation is important in the urban fringe, but is reduced in the center of the city by the anthropogenic effect. The annual temperature range is high (19 degrees) due to the large distance to the sea and altitude.

The annual rainfall is above 400 mm, with very marked minimum in summer (dry four months, from June to September) and large area oscillations between NW area, far more rainy, and the SE area is more arid.

**Table 1: General information of HUSA Chamartin building**

Name	HUSA Chamartín Hotel	Enveloped area	12.873m <sup>2</sup>
Address	Agustín de Foxá Street	Glazed area	4.737m <sup>2</sup> (37%)
City / Post code	Madrid/ 28036	From factor (S/V)	0.437
Country	Spain	Heated Area (m <sup>2</sup> )	15.875m <sup>2</sup>
Contact Person	Javier Martín	Heated Volume (m <sup>3</sup> )	44.450m <sup>3</sup>
e-mail of contact person	javier.martin@dalkia.es	Cooled Area (m <sup>2</sup> )	15.875m <sup>2</sup>
Location (coordinates)	Latitude: 40° 28' 19" N Longitude: 3° 41' 0" W	Cooled Volume (m <sup>3</sup> )	44.450m <sup>3</sup>
Orientation	N S W E	Heating degree days (15.5°C)	1.471
Altitude (m)	667	Cooling degree days (15.5°C)	1.443

Year of construction	1.982	Average power consumption (kWh/m <sup>2</sup> a)	n.a.
Typology of building	Hotel	Average thermal consumption (kWh/m <sup>2</sup> a)	
Floors	16	Heating system	Gas boilers Fancoils
Built area	34.834 m <sup>2</sup>	Cooling system	Chiller Fancoils
Net usable area	28.935 m <sup>2</sup>	DHW system	Gas boilers


**Table 2: Climate values for Madrid**

	T (°C)	TM (°C)	Tm (°C)	R (mm)	RH (%)	DR (d)	DN (d)	DT (d)	DF (d)	DH (d)	DD (d)	I (h/mo)
<b>Jan</b>	6.1	9.7	2.6	37	71	6	1	0	5	6	8	148
<b>Feb</b>	7.9	12.0	3.7	35	65	6	1	0	4	3	6	157
<b>Mar</b>	10.7	15.7	5.6	26	54	5	0	1	2	1	7	214
<b>Apr</b>	12.3	17.5	7.2	47	55	7	0	1	1	0	5	231
<b>May</b>	16.1	21.4	10.7	52	54	8	0	3	0	0	4	272
<b>Jun</b>	21.0	26.9	15.1	25	46	4	0	3	0	0	8	310
<b>Jul</b>	24.8	31.2	18.4	15	39	2	0	3	0	0	16	359
<b>Aug</b>	24.4	30.7	18.2	10	41	2	0	2	0	0	14	335
<b>Sep</b>	20.5	26.0	15.0	28	50	3	0	2	0	0	9	261
<b>Oct</b>	14.6	19.0	10.2	49	64	6	0	1	1	0	6	198
<b>Nov</b>	9.7	13.4	6.0	56	70	6	0	0	5	1	7	157
<b>Dec</b>	7.0	10.1	3.8	56	74	7	1	0	6	4	7	124
<b>Total</b>	14.6	19.4	9.7	436	57	63	4	16	24	16	97	2769

T: monthly average temperature; TM: monthly average of highest daily temperatures; Tm: monthly average of lowest daily temperatures; R: monthly average of rainfall; RH: monthly average of relative humidity; DR: monthly average of rainy days (rainfall  $\geq 1\text{mm}$ ); DN: monthly average of snow days; DT: monthly average of storm days; DF: monthly average of foggy days; DH: monthly average of frost days; DD: monthly average of cloudless days; I: monthly average of sunny hours.

## 2 Building use: distribution and occupancy

HUSA Chamartín Hotel has a rectangular plan with sixteen floors. In the ground floor there are offices and storage room.



**Figure 4: Floor +0.00 plan**

**Table 3: HCH building distribution / usage floor +0.00**

Zone	Floor	Useful area (m <sup>2</sup> )	H. (m)	Vol. (m <sup>3</sup> )	% cond.	Occ. (pax)	Cond. services
Storage room	0	225.05	3.00	675.15	0%	-	-
Air conditioning units room	0	27.05	3.00	81.15	0%	-	-
Office	0	55.05	3.00	165.15	0%	3	-
Bathroom 01	0	6.80	3.00	20.4	0%	-	-
Bathroom 02	0	6.80	3.00	20.4	0%	-	-
Waste room	0	8.55	3.00	25.65	0%	-	-
Hall + hallway	0	117.72	3.00	353.16	0%	-	-

In the first floor there are changing rooms and laundry.




**Figure 5: Floor +3.30 plan**

**Table 4: HCH building distribution / usage floor +3.30**

Zone	Floor	Useful area (m <sup>2</sup> )	H. (m)	Vol. (m <sup>3</sup> )	% cond.	Occ. (pax)	Cond. services
Changing room 01	1	81.15	3.00	243.45	0%	-	-
Changing room 02	1	80.15	3.00	240.45	0%	-	-
Changing room 03	1	16.60	3.00	49.8	0%	-	-
Living room	1	151.35	3.00	454.05	0%	-	-
Laundry	1	203.15	3.00	609.45	0%	-	-
Storage room 01	1	17.50	3.00	52.5	0%	-	-
Storage room 02	1	21.00	3.00	63	0%	-	-
Hall + hallway	1	143.68	3.00	431.04	0%	-	-

In the second floor there is the hotel access.




**Figure 6: Floor +6.60 plan**

**Table 5: HCH building distribution / usage floor +6.60**

Zone	Floor	Useful area (m <sup>2</sup> )	H. (m)	Vol. (m <sup>3</sup> )	% cond.	Occ. (pax)	Cond. services
Hall + hallway	2	80.50	3.00	241.15	100%	-	AHU


In the third floor there are offices.



**Figure 7: Floor +9.90 plan**
**Table 6: HCH building distribution / usage floor +9.90**

Zone	Floor	Useful area (m <sup>2</sup> )	H. (m)	Vol. (m <sup>3</sup> )	% cond.	Occ. (pax)	Cond. services
Office 01	3	102.00	3.00	306.00	100%	-	AHU
Office 02	3	18.50	3.00	55.50	100%	-	AHU
Office 03	3	14.50	3.00	43.50	100%	-	AHU
Office 04	3	66.50	3.00	199.50	100%	-	AHU
Office 05	3	19.00	3.00	57	100%	-	AHU
Office 06	3	18.15	3.00	54.45	100%	-	AHU
Office 07	3	22.65	3.00	67.95	100%	-	AHU
Hall + hallway	3	156.80	3.00	470.4	100%	-	AHU


In the fourth floor there are offices, meeting rooms, bar and restaurant.


**Figure 8: Floor +13.05 plan**
**Table 7: HCH building distribution / usage floor +13.05**

Zone	Floor	Useful area (m <sup>2</sup> )	H. (m)	Vol. (m <sup>3</sup> )	% cond.	Occ. (pax)	Cond. services
Office 01	4	9.50	3.00		100%	-	AHU
Office 02	4	18.35	3.00		100%	-	AHU

Office 03	4	41.40	3.00		100%	-	AHU
Office 04	4	13.50	3.00		100%	-	AHU
Office 05	4	16.70	3.00		100%	-	AHU
Office 06	4	63.40	3.00		100%	-	AHU
Office 07	4	15.20	3.00		100%	-	AHU
Bathroom 01	4	20.50	3.00		100%	-	AHU
Bathroom 02	4	25.15	3.00		100%	-	AHU
Bar	4	90.30	3.00		100%	-	AHU
Restaurant	4	130.68	3.00		100%	-	AHU
Hall + hallway	4	964.26	3.00		100%	-	AHU

In the fifth floor there are meeting rooms and kitchen mainly.




**Figure 9: Floor +16.35 plan**

**Table 8: HCH building distribution / usage floor +16.35**

Zone	Floor	Useful area (m <sup>2</sup> )	H. (m)	Vol. (m <sup>3</sup> )	% cond.	Occ. (pax)	Cond. services
Meeting room 01	5	351.05	3.00	1053.15	100%	-	AHU
Meeting room 02	5	71.20	3.00	213.60	100%	-	AHU

Meeting room 03	5	94.20	3.00	282.60	100%	-	AHU
Storage room 01	5	88.05	3.00	264.15	100%	-	AHU
Storage room 02	5	31.00	3.00	93	100%	-	AHU
Bathroom 01	5	16.10	3.00	48.3	0%	-	-
Bathroom 02	5	16.10	3.00	48.3	0%	-	-
Bathroom 03	5	7.20	3.00	21.6	0%	-	-
Wardrobe	5	19.20	3.00	57.6	0%	-	-
Kitchen	5	70.92	3.00	212.76	0%	-	-
Hall + hallway	5	526.38	3.00	1579.15	100%	-	AHU

In the sixth floor there are no rooms, is the technical floor.




**Figure 10: Floor +19.25 plan**

**Table 9: HCH building distribution / usage floor +19.25**

Zone	Floor	Useful area (m <sup>2</sup> )	H. (m)	Vol. (m <sup>3</sup> )	% cond.	Occ. (pax)	Cond. services
Technical floor	6	1250	3.00	3750	0%	-	-

In the floors 7 to 16 there are rooms.



**Figure 11: Floor 7 to 16 plan**


**Table 10: HCH building distribution / usage floor 7 to 16**

Zone	Floor	Useful area	H. (m)	Vol. (m <sup>3</sup> )	% cond.	Occ. (pax)	Cond. services

		(m <sup>2</sup> )					
Rooms 01 to 24	7 – 16	18.75	3.00	56.25	100%	1 - 2	FANCOILS
Rooms 25 - 43	7 – 16	20.35	3.00	61.05	100%	1 - 2	FANCOILS
Hallway	7 – 16	144.60	3.00	433.80	100%	-	AHU
Hall	7 – 16	31.21	3.00	93.63	100%	-	AHU

**Table 11: Building daily occupation profile of HUSA Chamartin building<sup>1</sup>**


Hour	1	2	3	4	5	6	7	8	9	10	11	12
Mon-Fri	1	1	1	1	1	1	1	1	1	1	1	1
Weekend	1	1	1	1	1	1	1	1	1	1	1	1
Hour	13	14	15	16	17	18	19	20	21	22	23	24
Mon-Fri	1	1	1	1	1	1	1	1	1	1	1	1
Weekend	1	1	1	1	1	1	1	1	1	1	1	1


**Figure 12: Building daily occupation**
**Table 12: Building yearly occupation profile of HUSA Chamartin building**

Week	1	2	3	4	5	6	7	8	9	10	11	12	13
Mon-Fri	1	1	1	1	1	1	1	1	1	1	1	1	1
Weekend	1	1	1	1	1	1	1	1	1	1	1	1	1
Week	14	15	16	17	18	19	20	21	22	23	24	25	26
Mon-Fri	1	1	1	1	1	1	1	1	1	1	1	1	1
Weekend	1	1	1	1	1	1	1	1	1	1	1	1	1
Week	27	28	29	30	31	32	33	34	35	36	37	38	39
Mon-Fri	1	1	1	1	1	1	1	1	1	1	1	1	1
Weekend	1	1	1	1	1	1	1	1	1	1	1	1	1

<sup>1</sup> (Not occup.=0; partially occup.=1; occup.=2)

<b>Week</b>	<b>40</b>	<b>41</b>	<b>42</b>	<b>43</b>	<b>44</b>	<b>45</b>	<b>46</b>	<b>47</b>	<b>48</b>	<b>49</b>	<b>50</b>	<b>51</b>	<b>52</b>
<b>Mon-Fri</b>	1	1	1	1	1	1	1	1	1	1	1	1	1
<b>Weekend</b>	1	1	1	1	1	1	1	1	1	1	1	1	1




**Figure 13: Building yearly occupation**

### 3 Building characteristics

#### 3.1 Envelope elements and thermal characteristics

**Table 13: Construction elements of HUSA Chamartin building**

Envelope Element	Description (material and thickness)	Total thick. (m)	U-Value (W/m <sup>2</sup> K)	Abs int. – abs ext	Details section'sketch from inner face to outer face
External wall	1 Brick 0,250 2 EPS 0,04 3 Brick 0,125 4 Plaster 0,005	0.415	0.44		
Internal wall	1 Plaster 0.005 2 Perforated brick 0.090 3 Plaster 0.005	0.100	2.13		
Roof	1 Concrete block 0,100 2 Concrete block 0,400 3 EPS 0.040 4 Air cavity unventilated 0.100 5 Plaster 0,020	0.660	0.52		
Floor	1 Concrete 0.350 2 Concrete 0.100 3 Cement 0.005 4 Ceramic tile 0.010	0.465	2.50		

**Table 14: Windows description of HUSA Chamartin building**

Envelope Element	Description	U-Value (W/m <sup>2</sup> K)	g	Details section sketch from inner face to outer face
Window	1 Vertical Blinds 2 Aluminium woodwork 3 Double glass 6+4	3.0	n.a.	

## 4 Energy flow

HUSA Chamartín Hotel has a system that can provide cold or heat. Boilers and chillers work against two storage tanks. Exchangers distributed heat or cold to the AHU and fan coils circuits.




Figure 14: Energy flow




Figure 15: Hydraulic scheme for heating and cooling system

**Table 15: Energy flow elements of HUSA Chamartin building**


HVAC PLANT	Installed system	Nº units	Picture
<b>Heating</b>	<b>Gas Boiler</b> ADISA DUPLEX 500 Heating Power: 472kW Max. temperature: 110°C Working pressure: 6bar	4	
<b>Cooling</b>	<b>Chiller</b> TRANE RTHC C1C32B Cooling power: 780kW	2	
<b>Storage</b>	<b>Heat storage</b> Volume: 750 l	2	
<b>DHW</b>	<b>Accumulators</b> Volume: 5.000 l	2	
<b>Terminal Units</b>	<b>Fancoils</b>	387	
	<b>Radiators</b>	460	

## 5 Energy supply and use

### 5.1 Electricity supply and consumption

**Table 16: Information about electricity supply of HUSA Chamartin building**

<b>Energy supplier (Name of organization)</b>	IBERDROLA					
<b>Tariff</b>						
<b>Nº tariff periods</b>	6					
<b>Periods</b>	1	2	3	4	5	6
<b>Contracted power (kW)</b>	n.a.	n.a.	n.a.	n.a.	n.a.	n.a.
<b>€/kW</b>	n.a.	n.a.	n.a.	n.a.	n.a.	n.a.
<b>€/kWh</b>	n.a.	n.a.	n.a.	n.a.	n.a.	n.a.



**Figure 16: Electricity consumption for cooling system**

**Table 17: Electricity consumption of HUSA Chamartin building**

	Jan	Feb	Mar	Apr	May	Jun
<b>kWh</b>	0	0	0	0	13.139	38.827
<b>€</b>	0	0	0	0	647,75	1.914,17
	Jul	Aug	Sep	Oct	Nov	Dec
<b>kWh</b>	41.214	47.784	34.009	2.054	0	0
<b>€</b>	2.031,85	2.355,75	1.676,64	101,26	0	0

**Total (kWh):** 177.027

**Total (€):** 8.727,42

## 5.2 Fuel supply and consumption

**Table 18: Information about fuel supply of HUSA Chamartin building**

<b>Energy supplier (Name of organization)</b>	
<b>Contracted energy/flow</b>	-
<b>Tariff</b>	n.a.
<b>Nº tariff periods</b>	n.a.
<b>€/kWh</b>	Variable
<b>€/kWh Special Tax Hydrocarbon</b>	n.a.

**Table 19: Gas consumption of HUSA Chamartin building**

	<b>Jan</b>	<b>Feb</b>	<b>Mar</b>	<b>Apr</b>	<b>May</b>	<b>Jun</b>
<b>kWh</b>	545.301	553.857	413.607	387.112	254.965	115.961
<b>€</b>	37.773,16	19.473,19	16.313,63	18.068,09	12.031,50	5.492,08
	<b>Jul</b>	<b>Aug</b>	<b>Sep</b>	<b>Oct</b>	<b>Nov</b>	<b>Dec</b>
<b>kWh</b>	101.558	112.703	118.817	181.889	389.828	295.194
<b>€</b>	4.850,38	5.430,28	5.722,85	8.741,77	18.713,66	14.179,74

**Total (kWh):** 3.470.792


**Total (€):** 166.790,33

## 6 Building Management System


HUSA Chamartín Hotel is provided with a monitoring and control system in the boilers and chillers rooms. The system only has control over energy production and is located in boilers/chillers rooms. The variable to control energy production is the return temperature.

### 6.1 Energy generation monitoring and control

There is commercial software developed by TREND for visualization features of their control system. The application can display real-time operating variables.



**Figure 17: Heat production management of HCH**



**Figure 18: Cold production management of HCH**

**Table 20: BMS installed devices and power balance of HUSA Chamartin building**

Device	Model	Manufacturer	Power (W)	Voltage (V)
Controller	IQ 221	TREND CONTROLS	10	230
Controller	IQ 222	TREND CONTROLS	10	230
Controller	IQ 223	TREND CONTROLS	10	230
Controller	IQ 228	TREND CONTROLS	10	230
Temperature sensor	TB/TI	TREND CONTROLS		
External Temperature sensor	TB/TI	TREND CONTROLS		
Energy meter		SIEMENS		
Energy meet		CIRCUTOR		


## 6.2 Control strategies

### **6.2.1 Heating and cooling system**


Control strategy for heating systems is based on external temperature and regulated by return temperature in each circuit.

**Table 21: Systems level control strategies of HUSA Chamartin building**


<b>Heating System</b>	Programming	WINTER: 1 <sup>st</sup> OCT – 1 <sup>st</sup> MAY
	Days	EVERY DAY
	Set points	Depend external temperature
	Scheduling	00:00 h – 23:59 h
<b>Cooling System</b>	Programming	SUMMER: 1 <sup>st</sup> MAY – 1 <sup>st</sup> OCT
	Days	EVERY DAY
	Set points	Depend external temperature
	Scheduling	00:00 h – 23:59 h



**Figure 19: Strategy for boiler start**



**Figure 20: Strategy for boilers sequencing**



**Figure 21: Strategy for boiler power limitation**




Figure 22: Strategy for boilers rotation by impairments




Figure 23: Strategy for gas meter




Figure 24: Strategy for fan tower






Figure 25: Strategy for energy balance



**Figure 26: Strategy for boilers thermal energy**



**Figure 27: Strategy for DHW pumps starts**




Figure 28: Strategy for DHW pumps operating hours






Figure 29: Strategy for cooling units' electrical consumption




**Figure 30: Strategy for cooling units thermal energy counters**



**Figure 31: Strategy for cooling units' production yields**

### 6.2.2 Generation level existing control




**Figure 32: Heat generation scheme**

**Table 22: Boiler related sensors**

System	ID	Description	Unit
Boiler	T1	Outdoor temperature	°C
	T2	DHW Tank 1 temperature	°C
	T3	DHW Tank 2 temperature	°C
	T4	Heat Supply temperature from boiler	°C
	T5	Heat Return temperature to boiler	°C
	T6	DHW Supply temperature	°C
	T7	DHW Return temperature	°C
	P1	Pump 1 DHW	On - Off
	P2	Pump 2 DHW	On - Off
	H1	Heat meter 1	Mw/h
	H2	Heat meter 2	Mw/h

**Table 23: Boiler related control**

System	ID	Description	Control
Boiler	Boilers On - Off	The permission to start and stop the boilers is managed by schedule.	Schedule Heat Schedule DHW
	P1	Pump DHW Tank 1	On → If set point is low than temperature in DHW Tank 1
	P2	Pump DHW Tank 2	On → If set point is low than temperature in DHW Tank 1


**Figure 33: Cooling generation scheme**
**Table 24: Chiller related sensors**

System	ID	Description	Unit
Chiller	T1	Cooling tower 1 temperature	°C
	T2	Cooling tower 2 temperature	°C
	T3	Discharge chiller 1 temperature	°C
	T4	Discharge chiller 2 temperature	°C
	H1	Heat meter 1	Mw/h

	H2	Heat meter 2	Mw/h
	E1	Electric meter 1	Mw/h
	E2	Electric meter 2	Mw/h

**Table 25: Chiller related control**

System	ID	Description	Control
Chiller	Chillers On - Off	The permission to start and stop the chillers is managed by schedule.	Schedule Cool Mode

## 7 Historical data: existing data base

### 7.1 Existing data base

There is no database in HUSA Chamartin building.

### 7.2 Existing historical variables

**Table 26: Consumed energy parameters of HUSA Chamartin building**


<b>Consumed Energy</b>				
<b>Concept</b>	<b>Application</b>		<b>Measurement<sup>2</sup></b>	<b>Monitoring point and location</b>
<b>Fossil fuel (biomass, natural gas, etc.)</b>	Heating	Y	F+HC	Boilers room
	Cooling	N		
	DHW	Y	F+HC	Boilers room
<b>Electricity</b>	Heating			
	Cooling	Y	E+HC	Boilers room
	DHW			
	Ventilation	Y	E	Boilers room
	Lighting	Y	E	
	Appliances	Y	E	
<b>District energy</b>	District heating			
	District cooling			

**Table 27: Delivered energy parameters of HUSA Chamartin building**

<b>Delivered energy</b>				
<b>Concept</b>	<b>No.</b>		<b>Explanation</b>	<b>Unit</b>
<b>Heating system</b>	1	t <sub>1</sub>	Boiler flow temperature	°C
	2	t <sub>2</sub>	Boiler return temperature	°C
	3	t <sub>3</sub>	Tank 1 temperature	°C
	4	t <sub>4</sub>	Tank 2 temperature	°C
	5	E <sub>1</sub>	Thermal energy meter Boiler1	Mw/h
	6	E <sub>2</sub>	Thermal energy meter Boiler 2	Mw/h
	7	G <sub>1</sub>	Boilers Gas meter	m <sup>3</sup>
<b>Cooling</b>	8	t <sub>5</sub>	Cooling Tower 1 temperature	°C

<sup>2</sup> Electricity meter (E), Fuel meter (F), Water meter (W), Hot/cold water meter (HC), None (N)

<b>system</b>	9	$t_6$	Cooling Tower 2 temperature	°C
	10	$E_1$	Thermal energy meter Cooling Unit 1	Mw/h
	11	$E_2$	Thermal energy meter Cooling Unit 2	Mw/h
	12	$W_1$	Electrical meter Cooling Unit 1	Mw/h
	13	$W_2$	Electrical meter Cooling Unit 2	Mw/h
<b>Domestic Hot Water</b>	14	$t_7$	Domestic Hot Water flow temperature	°C
	15	$t_8$	Domestic Hot Water return temperature	°C


**Figure 34: Boiler flow temperature**
**Table 28: Indoor ambient parameters of HUSA Chamartin building**

Indoor ambient parameters				
Concept	Measurement		Quantity	Monitoring point and location
<b>Indoor conditions</b>	Temperature	N		
	Relative humidity	N		
	Illumination level	N		
	CO <sub>2</sub> concentration	N		

	Occupancy	N		
	Window status	N		

## 8 External data sources: weather data

There is an external temperature sensor in a boiler room.

**Table 29: Outdoor ambient parameters of HUSA Chamartin building**

Outdoor ambient parameters				
Concept	No.		Explanation	Unit
Outdoor ambient param.	1	$t_{ext}$	Ambient temperature	°C